



LSG ELAB

Bankverbindungen:
Deutsche Bank AG, Frankfurt
Kto.-Nr. 600011100, BLZ 500 70010
Sparkasse Siegen
Kto.-Nr. 30 375 984, BLZ 460 500 01

USt-IdNr.: DE 164903772

St-Nr. LH 5214/5822/0047

Telefon 02 71/77 50-3
Telefax 02 71/77 50-500
E-Mail lsg-elab@lsg-elab.de

LSG-ELAB GmbH
Birlenbacher Str. 14, D-57078 Siegen

Schäfer-Werke GmbH
z. Hd. Herrn Sebastian Hilpisch
Pfannenbergstr. 1

57290 Neunkirchen



DAP-PL-3072.00
DAP-ZE-3072.01

Ihr Zeichen/Datum	Unsere Durchwahl	Unsere Telefax-Durchwahl	Unser Zeichen/Datum
	-464	-501	sm/ 23.02.2004

Test-Report **W04-00673M**

Order: Analysis

Customer: Schäfer-Werke GmbH
z. Hd. Herrn Sebastian Hilpisch
Pfannenbergstr. 1

57290 Neunkirchen

Results of W04-00673M from 12.02.2004.

Remarks only in relation to examined samples.

To duplicate the examination report in parts, a written permission given by LSG-ELAB GmbH is required.

Test-Report
W04-00673M

Customer: Schäfer-Werke GmbH, Neunkirchen
Appearance: colourless / clear
Sampling site: DWS 30 manual, Sample from dispensing valve after disinfection
Sampling date: 12.02.2004 / 16:00 Uhr **Operator:** Laboratory
Date of testing (start): 12.02.2004 **Date of testing (end):** 23.02.2004

Parameter	Dimension	Result	Limit (TrinkwV)		Procedure
			not under	not over	
Colony count 20 °C	1/ml	0		100	TrinkwV a.F.*
Colony count 36 °C	1/ml	0		100	TrinkwV a.F.*
E. coli	1/100ml	0		0	ISO 9308-1*
Coliforms	1/100ml	0		0	ISO 9308-1*
P. aeruginosa	1/100ml	0		0	prEN ISO 12780*

Notes: * = certified parameter; ** = parameter examined in a other certified institute; n.n. = not detected; n.b. = not analysed

Remarks only in relation to examined microbiological parameters.


Comments:

System filled by orderer on February 12th 2004.
 Content of DWS 30 manual: approx. 15 l.
 Origin of water: Herdorf purification plant, 3rd level of water purification (see W04-00672M).

Sample evaluation:

The results meet the requirements for drinking water given by the german drinking water regulation.

LSG-ELAB GmbH



Oliver Schulte-Mäter
Food Chemist